



**GRAFTON**  
Massachusetts

Katrina Koshivos <koshivosk@grafton-ma.gov>

---

**ZBA Case #879 - 20 Brielle Road - Variance**

1 message

Nancy Connors <connorsn@grafton-ma.gov>  
To: Zoning Department <zba@grafton-ma.gov>

Tue, Oct 19, 2021 at 5:57 PM

If property is on private septic, the shed needs to be 10 feet from the septic tank and 20 feet from the leach field. Thank you.

Nancy Connors

Office Manager

Town of Grafton

Health Department

30 Providence Road

Grafton, MA 01519

Phone: 508-839-5335 X 1119

Fax: 508-839-8559

[connorsn@grafton-ma.gov](mailto:connorsn@grafton-ma.gov)

[www.grafton-ma.gov](http://www.grafton-ma.gov)

**Follow Us:** [Facebook](#) |

*When responding, please remember the Secretary of State considers e-mail a public record.*

♻️ **Consider the environment before printing this e-mail.**

**PLEASE BE ADVISED, THE NEW HOURS AT THE MUNICIPAL CENTER EFFECTIVE 7/5/2021 ARE AS FOLLOWS:**

**MONDAY, WEDNESDAY, & THURSDAY 8:30-4:30**

**TUESDAY 8:30 - 7:00 P.M.**

**FRIDAY 8:30 - 1:00 P.M.**

RECEIVED

OCT 21 2021

Zoning Board of Appeals

RECEIVED TOWN OF GRAFTON  
OCT 21 2021 PM 2:41